

**Brookhaven National Laboratory
Plant Engineering - E&CS Division
Engineering Change Notice Form**

PROJECT: CCWF II

JOB No. 11705

ECN Title: Cooling Tower Damproofing

ECN No. 8

Affected Documents: SC-120, Specification Section 07110

Requested Change (Attach sketch if applicable): Damproofing is not required on the exterior of the cooling tower wet well or basin.

Requested by: A. Raphael

Date: 10/13/09

Resolution: Delete Note 6 on Dwg. SC-120

Approvals: A/E or Proj. Eng.:

Date:

Project Coordinator:

Date: 10/13/09

Manager:

Date: 10/13/09

Contractor shall take the following action:

☐ Await change order from P&PM

☒ Proceed with change as described

☒ Provide cost proposal for change as described

Distribution: E. W. Howell

Giffels

E&U

MPO

O&M

DOE

NSLS II

ECN File